

Determination of the filtration performance of air filter UAB FIBERTON
592x592x48 according to EN ISO 16890:2016



Requested by **Fiberton Ltd**
Laurynas Lukošius
Lakūnų g. 3A
LT - LT-09108 Vilnius
lab@fiberton.eu

Order ref. Q3JAPT230002-02, dated 16.1.2023

Contact person **Eurofins Expert Services Oy**
Antti Korhonen
Tekniikantie 4 B
02150 Espoo, Finland
AnttiKorhonen@eurofins.fi

Assignment	Determination of the filtration performance of air filter UAB FIBERTON 592x592x48 according to EN ISO 16890:2016
Sample details	<p>The customer delivered two air filters, from which one was randomly selected for tests, which is detailed in Appendix 1.</p> <p>The sample were received 19.1.2023. The measurements were made 25.1. - 6.2.2023.</p>
Methods	<p>The tests were made according to EN ISO 16890:2016 standard series /1, 2, 3 and 4/</p> <p>The filter discharging treatment were made by exposing it to isopropanol vapor. The purity of the isopropanol used in the test was $\geq 99.5\%$.</p> <p>The air flow rates were measured with a calibrated orifice plate with corner pressure tappings.</p> <p>The instruments used in the measurements are presented in Appendix 8.</p> <p>FINAS Finnish Accreditation Service has accredited our laboratory (T001, Appendix 1.08, Eurofins Expert Services Oy) to perform measurements according to EN ISO 16890:2016 standard series.</p>
Results	<p>A summary of the test results, fractional efficiency values and calculation of the particulate matter efficiencies (ePM) are presented in Appendix 1. The test dust capacity has been interpolated/extrapolated to the final pressure drop.</p> <p>Initial and conditioned fractional efficiency measurement results are presented in accordance with EN ISO 16890-2:2016 and EN ISO 16890-4:2016 in Appendix 2.</p> <p>Dust loading and pressure drop measurement results are presented in accordance with EN ISO 16890-3:2016 in Appendix 3.</p> <p>Test aerosol particle numbers measured in determination of initial fractional efficiency is presented in Appendix 4 and for conditioned fractional efficiency in Appendix 5.</p> <p>The net effective filtering area 5.6 m^2 was calculated using the following measured approximate dimensions: pleat depth 42 mm, pleat tip width 1 mm pleat width 590 mm, number of pleats per filter pack 110, number of packs in the filter 1.</p> <p>Normalized downstream particle size distributions and measured efficiencies in standardized environments are presented in Appendix 6.</p> <p>The EN ISO 16890-1:2016 guideline for interpretation of test reports is presented in Appendix 7.</p> <p>The measurements have been made so that the accuracy demands set in the standard ISO 16890-2 are fulfilled, i.e. pressure difference accuracy $\pm 2\text{ Pa}$ in the range 0 - 70 Pa, above 70 Pa 3 % of the measured value, uncertainty of air flow rate $\leq 5\%$ at a 95 % confidence level.</p> <p>The results are only valid for the tested filter sample.</p>

References

/1/ EN ISO 16890-1:2016. Air filters for general ventilation - Part 1: Technical specifications, requirements and classification system based upon particulate matter efficiency (ePM)

/2/ EN ISO 16890-2:2022. Air filters for general ventilation - Part 2: Measurement of fractional efficiency and air flow resistance

/3/ EN ISO 16890-3:2016. Air filters for general ventilation - Part 3: Determination of the gravimetric efficiency and the air flow resistance versus the mass of test dust captured

/4/ EN ISO 16890-4:2022. Air filters for general ventilation - Part 4: Conditioning method to determine the minimum fractional test efficiency

Espoo, 7.2.2023

Antti Korhonen

Expert

Appendices 8
Distribution Customer, electronically approved

EN ISO 16890-1:2016 Air Filter Test Results

GENERAL

Test no.:	224772	Device receiving date:	19.1.2023
Test requested by:	Fiberton Ltd	Date of test:	25.1. - 6.2.2023
Device delivered by:	Fiberton Ltd	Operator:	RB
		Supervisor:	AK

DEVICE TESTED

Model		Manufacturer	Construction
UAB FIBERTON 592x592x48		Fiberton Ltd	Panel
Type of medium	Net effective filtering area	Filter dimensions (width × height × depth)	
Synthetic	5.6 m ²	592 mm x 592 mm x 48 mm	

TEST DATA



Test air flow rate	Test air temperature	Test air relative humidity	Test aerosol	Loading dust
0.944 m ³ /s	20 - 23 °C	41 - 52 %	DEHS and KCl	ISO 12103 A2 Fine

CONDITIONING ENVIRONMENT

Time of conditioning	Room temperature	Room relative humidity	Barometric pressure	Evaporated IPA amount
24 h	17 - 18 °C	39 - 46 %	97.7 - 99.3 kPa	292.5 g

RESULTS

Initial pressure drop	Initial grav. arrestance (5 g)	ePM _{1, min}	ePM _{2.5, min}	ISO rating
90 Pa	87 %	12 %	27 %	
Final test pressure drop	Test dust capacity	ePM ₁	ePM _{2.5}	ISO ePM ₁₀ 65 %
300 Pa	58 g	17 %	32 %	
Remarks: -				



NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot be themselves be quantitatively applied to predict filtration performance in all "real life" environments.



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Fractional efficiency values
EN ISO 16890-1,2,4:2016

Air filter: UAB FIBERTON 592x592x48

Test no.: 224772

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 0.944 m³/s

OPC Bin, <i>i</i>	Particle size			Fractional efficiency		
	Δd_i µm	\bar{d}_i µm	$\Delta \ln d_i$ µm	E_i %	$E_{D,i}$ %	$E_{A,i}$ %
1	0.30 - 0.41	0.35	0.31237	14	6	10
2	0.41 - 0.55	0.47	0.29376	19	9	14
3	0.55 - 0.70	0.62	0.24116	26	15	21
4	0.70 - 1.00	0.84	0.35667	34	24	29
5	1.00 - 1.30	1.14	0.26236	59	46	52
6	1.30 - 1.60	1.44	0.20764	65	55	60
7	1.60 - 2.20	1.88	0.31845	71	61	66
8	2.20 - 3.00	2.57	0.31015	78	70	74
9	3.00 - 4.00	3.46	0.28768	85	78	82
10	4.00 - 5.50	4.69	0.31845	87	83	85
11	5.50 - 7.00	6.20	0.24116	85	85	85
12	7.00 - 10.00	8.37	0.35667	88	86	87

Symbols and units

- Δd_i Particle size range *i*, µm
- \bar{d}_i Geometric mean diameter of a size range *i*, µm
- $\Delta \ln d_i$ Logarithmic width of particle diameter size range *i*
- E_i Initial fractional efficiency of particle size range *i* of the untreated and unloaded filter element, %
- $E_{D,i}$ Fractional efficiency of particle size range *i* of the filter element after an artificial conditioning step, %
- $E_{A,i}$ Average fractional efficiency of particle size range *i*, %

**Calculation of the particulate matter efficiencies (ePM)
EN ISO 16890-1:2016**

Air filter: UAB FIBERTON 592x592x48

Test no.: 224772

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 0.944 m³/s

OPC Bin, <i>i</i>	Particle size			Urban size distribution					
	Δd_i µm	\bar{d}_i µm	$\Delta \ln d_i$ µm	$q_{3u}(\bar{d}_i)$	$q_{3u}(\bar{d}_i) *$ $\Delta \ln d_i$	$E_{D,i} * q_{3u}(\bar{d}_i)$ $* \Delta \ln d_i$	$E_{A,i} * q_{3u}(\bar{d}_i)$ $* \Delta \ln d_i$	$ePM_{x, \min}$ %	ePM_x %
1	0.30 - 0.41	0.35	0.31237	0.225685	0.070498	0.004218	0.007193		
2	0.41 - 0.55	0.47	0.29376	0.197321	0.057965	0.005423	0.008269		
3	0.55 - 0.70	0.62	0.24116	0.158372	0.038193	0.005665	0.007854		
4	0.70 - 1.00	0.84	0.35667	0.115223	0.041097	0.009912	0.012008	$ePM_{1, \min}$	ePM_1
Σ line 1-4				0.207754	0.025219	0.035325	12	17	
5	1.00 - 1.30	1.14	0.26236	0.085032	0.022309	0.010176	0.011642		
6	1.30 - 1.60	1.44	0.20764	0.076177	0.015817	0.008624	0.009480		
7	1.60 - 2.20	1.88	0.31845	0.080218	0.025546	0.015709	0.016918		
8	2.20 - 3.00	2.57	0.31015	0.099839	0.030966	0.021543	0.022890	$ePM_{2.5, \min}$	$ePM_{2.5}$
Σ line 1-8				0.302392	0.081270	0.096255	27	32	


OPC Bin, <i>i</i>	Particle size			Rural size distribution				
	Δd_i µm	\bar{d}_i µm	$\Delta \ln d_i$ µm	$q_{3r}(\bar{d}_i)$	$q_{3r}(\bar{d}_i) *$ $\Delta \ln d_i$	$E_{D,i} * q_{3r}(\bar{d}_i)$ $* \Delta \ln d_i$	$E_{A,i} * q_{3r}(\bar{d}_i)$ $* \Delta \ln d_i$	ePM_x %
1	0.30 - 0.41	0.35	0.31237	0.093806	0.029303	0.002990		
2	0.41 - 0.55	0.47	0.29376	0.083478	0.024522	0.003498		
3	0.55 - 0.70	0.62	0.24116	0.074324	0.017924	0.003686		
4	0.70 - 1.00	0.84	0.35667	0.070137	0.025016	0.007310		
5	1.00 - 1.30	1.14	0.26236	0.076281	0.020013	0.010444		
6	1.30 - 1.60	1.44	0.20764	0.088326	0.018340	0.010992		
7	1.60 - 2.20	1.88	0.31845	0.108042	0.034406	0.022786		
8	2.20 - 3.00	2.57	0.31015	0.137262	0.042573	0.031470		
9	3.00 - 4.00	3.46	0.28768	0.167084	0.048067	0.039293		
10	4.00 - 5.50	4.69	0.31845	0.195424	0.062233	0.052653		
11	5.50 - 7.00	6.20	0.24116	0.216707	0.052261	0.044391		
12	7.00 - 10.00	8.37	0.35667	0.231428	0.082545	0.071526		ePM_{10}
Σ line 1-12				0.457204		0.301038		66

Symbols and units

- Δd_i Particle size range *i*, µm
- \bar{d}_i Geometric mean diameter of a size range *i*, µm
- $\Delta \ln d_i$ Logarithmic width of particle diameter size range *i*
- $q_{3u}(\bar{d}_i)$ Discrete urban particle volume distribution, dimensionless
- $q_{3r}(\bar{d}_i)$ Discrete rural particle volume distribution, dimensionless
- $E_{D,i}$ Fractional efficiency of particle size range *i* of the filter element after an artificial conditioning step, %
- $E_{A,i}$ Average fractional efficiency of particle size range *i*, %
- $ePM_{x, \min}$ Minimum particulate matter efficiency value of the conditioned filter, %
- ePM_x Particulate matter efficiency, %

Initial and conditioned fractional efficiency
EN ISO 16890-2,4:2016

Air filter: UAB FIBERTON 592x592x48
 Test no.: 224772
 Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)
 Air flow rate: 0.944 m³/s



Particle size		Fractional efficiency and upstream concentration					
Δd_i	d_i	Initial, $q_v = 100\%$		Conditioned, $q_v = 100\%$		Conditioned, $q_v = 50\%$	
µm	µm	%	#/dm³	%	#/dm³	%	#/dm³
0.30 - 0.41	0.35	14.4	39 396	6.0	38 663	7.3	30 351
0.41 - 0.55	0.47	19.2	24 172	9.4	23 548	8.3	19 042
0.55 - 0.70	0.62	26.3	15 179	14.8	14 806	8.9	12 155
0.70 - 1.00	0.84	34.3	15 477	24.1	15 294	14.9	13 242
1.00 - 1.30	1.14	58.8	5 683	45.6	4 890		
1.30 - 1.60	1.44	65.4	5 256	54.5	4 517		
1.60 - 2.20	1.88	71.0	6 595	61.5	5 743		
2.20 - 3.00	2.57	78.3	4 156	69.6	3 696		
3.00 - 4.00	3.46	85.1	2 985	78.4	2 634		
4.00 - 5.50	4.69	86.7	1 509	82.5	1 257		
5.50 - 7.00	6.20	84.9	372	85.0	342		
7.00 - 10.00	8.37	87.7	309	85.6	302		
DEHS concentration		111 880		109 656			
KCl concentration		122 782		106 080			
Pressure drop		90 Pa		89 Pa			
Device mass		1589 g		1589 g			

Particle counter coincidence value is 250 000 #/dm³

Symbols and units

- Δd_i Particle size range, µm
- d_i Geometric mean diameter of a size range i, µm
- q_v Air flow rate at filter

Air flow rate and pressure drop after different dust loading phases
EN ISO 16890-2,3:2016

Air filter: UAB FIBERTON 592x592x48

Test no.: 224772

Air flow rate: 0.944 m³/s

Date	Loaded dust m _{tot} g	Calibrated orifice plate ¹⁾				Filter							% of rated air flow
		t _f °C	p _{sf} kPa	Δp _f Pa	q _m kg/s	t °C	φ %	p _a kPa	ρ kg/m ³	q _v m ³ /s	Δp Pa	Δp _{1,20} Pa	
Clean Filter													
25.1.2023	-	19.7	-0.173	1705	1.414	21.1	44.5	101.6	1.198	1.180	127	127	125 %
"	-	19.1	-0.125	1089	1.135	19.9	48.8	101.6	1.203	0.944	90	90	100 %
"	-	18.8	-0.087	612	0.854	19.6	50.3	101.6	1.204	0.709	58	58	75 %
"	-	19.7	-0.054	268	0.567	19.8	52.1	101.6	1.203	0.472	32	32	50 %
"	-	20.4	-0.030	67	0.285	20.1	51.4	101.6	1.202	0.237	12	12	25 %
Clean filter pressure drop is proportional to (q _v) ⁿ , where n = 1.454													
Conditioned filter													
31.1.2023	-	22.0	-0.124	1058	1.100	22.3	41.3	99.3	1.165	0.944	88	89	100 %
"	-	22.3	-0.055	259	0.549	22.5	41.1	99.3	1.165	0.472	31	32	50 %
Dust loading phase													
6.2.2023	8	20.7	-0.257	1111	1.152	20.7	43.2	103.3	1.221	0.944	107	106	
"	23	20.1	-0.298	1114	1.155	20.3	44.6	103.4	1.223	0.945	144	143	
"	38	21.5	-0.342	1106	1.147	21.6	43.3	103.4	1.217	0.943	191	190	
"	53	20.1	-0.401	1104	1.149	21.1	41.1	103.4	1.219	0.943	251	249	
"	63	19.6	-0.451	1110	1.152	20.5	43.8	103.3	1.221	0.944	303	301	

Symbols and units

m _{tot}	Cumulative mass of dust fed to filter, g	t _f	Temperature at air flow meter, °C
p _a	Absolute air pressure upstream of filter, kPa	ρ	Air density upstream of filter, kg/m ³
p _{sf}	Air flow meter static pressure, kPa	φ	Relative humidity upstream of filter, %
q _m	Mass flow rate, kg/s	Δp	Measured filter pressure drop, Pa
q _v	Air flow rate at filter, m ³ /s	Δp _f	Air flow meter differential pressure, Pa
t	Temperature upstream of filter, °C	Δp _{1,20}	Filter pressure drop at air density 1.20 kg/m ³ , Pa

¹⁾ Orifice plate dimensions

Duct dimensions:	610 mm x 610 mm
Orifice diameter:	216 mm

**Pressure drop and arrestance after different dust loading phases
EN ISO 16890-3:2016**

Air filter: UAB FIBERTON 592x592x48

Test no.: 224772

Air flow rate: 0.944 m³/s

Date	Δp_1 Pa	Δm g	m_{tot} g	Δp_2 Pa	m_1 g	m_2 g	Δm_{ff} g	m_d g	Δm_c g	$m_{c,tot}$ g	A %	A_m %
6.2.2023	89	8	8	106	2549.9	2550.9	1.0	0.0	7	7	87.5	-
"	106	15	23	143	2550.9	2552.3	1.4	0.0	14	21	90.7	-
"	143	15	38	190	2552.3	2553.2	0.9	0.0	14	35	94.0	-
"	190	15	53	249	2553.2	2554.0	0.8	0.0	14	49	94.7	-
"	249	10	63	301	2554.0	2554.5	0.5	0.0	10	58	95.0	92.7

Mass of tested device

Initial mass of tested device: 1588.9 g

Final mass of tested device: 1647.1 g

Symbols and units

A	Arrestance, %	Δm	Dust increment, g
A_m	Average arrestance, %	Δm_{ff}	Mass gain of final filter, g
m_d	Dust in duct after device, g	Δm_c	Captured dust increment, g
m_{tot}	Cumulative mass of dust fed to filter, g	$m_{c,tot}$	Cumulative mass of captured dust, g
m_1	Mass of final filter before dust increment, g	Δp_1	Pressure drop before dust increment (air density 1.20 kg/m ³), Pa
m_2	Mass of final filter after dust increment, g	Δp_2	Pressure drop after dust increment (air density 1.20 kg/m ³), Pa

Loading dust

Type: ISO 12103 A2 Fine
 Manufactured by: Particle Technology Ltd
 Batch no.: 10207 18/03/22

**Correlation data for initial efficiency
EN ISO 16890-2:2016**

Air filter: UAB FIBERTON 592x592x48
Test no.: 224772
Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)
Air flow rate: 0.944 m³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,c,b}$	$U_{B,c,f}$	$U_{B,c}$	$D_{B,c,b}$	$D_{B,c,f}$	$D_{B,c}$
1	0.35	1	0	0.5	0	1	0.5
2	0.47	0	0	0	0	0	0
3	0.62	1	0	0.5	0	1	0.5
4	0.84	0	0	0	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	0	0	0	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	1	0.5
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream correlation (five measurements)						Downstream correlation (five measurements)					$D_{c,tot}$
		1	2	3	4	5	$U_{c,tot}$	1	2	3	4	5	
1	0.35	39781	39243	39996	39934	40167	199121	38160	37706	37847	37764	38114	189591
2	0.47	24894	24030	24393	24241	24401	121959	25487	25617	25865	25258	25793	128020
3	0.62	15526	15014	15373	15135	15340	76388	15609	15557	15647	15807	15880	78500
4	0.84	15879	15645	15748	15753	16037	79062	15666	15431	15609	15641	15732	78079
5	1.14	5534	5432	5449	5441	5429	27285	5491	5544	5496	5468	5436	27435
6	1.44	5110	5135	5152	5171	5070	25638	4570	4595	4763	4718	4585	23231
7	1.88	6473	6395	6501	6492	6391	32252	6465	6295	6577	6250	6336	31923
8	2.57	4070	4093	4140	4161	4077	20541	4430	4237	4400	4385	4261	21713
9	3.46	2852	2830	2874	2858	2783	14197	2984	3016	3036	2874	3010	14920
10	4.69	1497	1517	1452	1440	1533	7439	1516	1643	1555	1625	1582	7921
11	6.20	387	389	375	388	360	1899	395	373	381	385	393	1927
12	8.37	338	355	302	322	321	1638	334	369	372	306	323	1704

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Correlation ratios (five measurements)						Uncertainty limits			
		R_1	R_2	R_3	R_4	R_5	R_{avg}	Pass/Fail	δ_c	e_c	Pass/Fail
1	0.35	0.959	0.961	0.946	0.946	0.949	0.952	Pass	0.0073	0.0091	Pass
2	0.47	1.024	1.066	1.060	1.042	1.057	1.050	Pass	0.0171	0.0212	Pass
3	0.62	1.005	1.036	1.018	1.044	1.035	1.028	Pass	0.0158	0.0197	Pass
4	0.84	0.987	0.986	0.991	0.993	0.981	0.988	Pass	0.0047	0.0058	Pass
5	1.14	0.992	1.021	1.009	1.005	1.001	1.006	Pass	0.0104	0.0129	Pass
6	1.44	0.894	0.895	0.924	0.912	0.904	0.906	Pass	0.0127	0.0158	Pass
7	1.88	0.999	0.984	1.012	0.963	0.991	0.990	Pass	0.0182	0.0226	Pass
8	2.57	1.088	1.035	1.063	1.054	1.045	1.057	Pass	0.0203	0.0252	Pass
9	3.46	1.046	1.066	1.056	1.006	1.082	1.051	Pass	0.0286	0.0355	Pass
10	4.69	1.013	1.083	1.071	1.128	1.032	1.065	Pass	0.0453	0.0563	Pass
11	6.20	1.021	0.959	1.016	0.992	1.092	1.016	Pass	0.0489	0.0607	Pass
12	8.37	0.988	1.039	1.232	0.950	1.006	1.043	Pass	0.1102	0.1368	Pass

Symbols and units

- \bar{d}_i Geometric mean diameter of a size range i, µm
- $U_{B,c,b}$ Upstream beginning background count for correlation
- $U_{B,c,f}$ Upstream final background count
- $U_{B,c}$ Upstream background count average for correlation
- $D_{B,c,b}$ Downstream beginning background count for correlation
- $D_{B,c,f}$ Downstream final background count
- $D_{B,c}$ Downstream background count average for correlation
- $U_{c,tot}$ Total upstream particle counts
- $D_{c,tot}$ Total downstream particle counts
- R_{avg} Average correlation ratio
- δ_c Standard deviation of the correlation values
- e_c Uncertainty at 95 % confidence interval for correlation values

Initial efficiency data
EN ISO 16890-2:2016

Air filter: UAB FIBERTON 592x592x48
Test no.: 224772
Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)
Air flow rate: 0.944 m³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,e,b}$	$U_{B,e,f}$	$U_{B,e}$	$D_{B,e,b}$	$D_{B,e,f}$	$D_{B,e}$
1	0.35	1	1	1	1	1	1
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	2	1	1.5	1	0	0.5
5	1.14	0	0	0	0	0	0
6	1.44	0	0	0	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	2	1
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream efficiency (five measurements)						Downstream efficiency (five measurements)					
		1	2	3	4	5	$U_{e,tot}$	1	2	3	4	5	$D_{e,tot}$
1	0.35	39579	39305	39277	39217	39602	196980	32167	32004	32322	32131	31879	160503
2	0.47	24208	24187	24135	24211	24118	120859	20521	20495	20627	20613	20297	102553
3	0.62	15168	15257	15199	15130	15140	75894	11562	11601	11331	11518	11479	57491
4	0.84	15429	15365	15524	15680	15388	77386	9928	9944	10152	10153	10019	50196
5	1.14	5439	5572	5623	5898	5881	28413	2280	2276	2332	2484	2412	11784
6	1.44	5004	5189	5339	5480	5269	26281	1597	1682	1629	1700	1639	8247
7	1.88	6427	6554	6525	6655	6815	32976	1831	1907	1842	1949	1950	9479
8	2.57	4024	4070	4095	4224	4366	20779	959	960	917	945	990	4771
9	3.46	2968	2911	3003	2927	3114	14923	460	489	486	463	433	2331
10	4.69	1507	1475	1549	1506	1508	7545	202	235	216	197	218	1068
11	6.20	407	352	380	353	367	1859	57	74	49	38	66	284
12	8.37	304	281	307	311	344	1547	32	49	45	34	37	197

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Observed penetration (five measurements)							δ_o
		P_{o1}	P_{o2}	P_{o3}	P_{o4}	P_{o5}	P_o		
1	0.35	0.813	0.814	0.823	0.819	0.805	0.815	0.007	
2	0.47	0.848	0.847	0.855	0.851	0.842	0.849	0.005	
3	0.62	0.762	0.760	0.746	0.761	0.758	0.758	0.007	
4	0.84	0.643	0.647	0.654	0.648	0.651	0.649	0.004	
5	1.14	0.419	0.408	0.415	0.421	0.410	0.415	0.006	
6	1.44	0.319	0.324	0.305	0.310	0.311	0.314	0.008	
7	1.88	0.285	0.291	0.282	0.293	0.286	0.287	0.004	
8	2.57	0.238	0.236	0.224	0.224	0.227	0.230	0.007	
9	3.46	0.155	0.168	0.162	0.158	0.139	0.156	0.011	
10	4.69	0.134	0.159	0.139	0.131	0.145	0.142	0.011	
11	6.20	0.140	0.210	0.129	0.108	0.180	0.153	0.041	
12	8.37	0.105	0.174	0.147	0.109	0.108	0.129	0.031	

OPC Bin, i	\bar{d}_i µm	Penetration data reduction			Uncertainty limits			Efficiency %
		P	δ	e	Static	Dynamic	Pass/Fail	
1	0.35	0.856	0.010	0.012	0.05	0.060	Pass	14.4
2	0.47	0.808	0.014	0.017	0.05	0.057	Pass	19.2
3	0.62	0.737	0.013	0.016	0.05	0.052	Pass	26.3
4	0.84	0.657	0.005	0.006	0.05	0.046	Pass	34.3
5	1.14	0.412	0.007	0.009	0.05	0.029	Pass	58.8
6	1.44	0.346	0.010	0.012	0.05	0.024	Pass	65.4
7	1.88	0.290	0.007	0.009	0.05	0.020	Pass	71.0
8	2.57	0.217	0.008	0.010	0.05	0.015	Pass	78.3
9	3.46	0.149	0.011	0.014	0.05	0.022	Pass	85.1
10	4.69	0.133	0.012	0.015	0.05	0.020	Pass	86.7
11	6.20	0.151	0.041	0.051	0.05	0.030	Pass	84.9
12	8.37	0.123	0.032	0.040	0.05	0.025	Pass	87.7

Symbols and units

- \bar{d}_i Geometric mean diameter of a size range i, µm
- $U_{B,e,b}$ Upstream beginning background count for penetration
- $U_{B,e,f}$ Upstream final background count
- $U_{B,e}$ Upstream background count average for penetration
- $D_{B,e,b}$ Downstream beginning background count for penetration
- $D_{B,e,f}$ Downstream final background count
- $D_{B,e}$ Downstream background count average for penetration
- $U_{e,tot}$ Total upstream particle counts
- $D_{e,tot}$ Total downstream particle counts
- P_o Observed penetration, -
- P Penetration, -
- δ_o Standard deviation of the observed penetration
- δ Standard deviation of the penetration
- e Uncertainty at 95 % confidence interval for penetration values



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

**Correlation data for conditioned efficiency
EN ISO 16890-2:2016**

Air filter: UAB FIBERTON 592x592x48
Test no.: 224772
Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)
Air flow rate: 0.944 m³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,c,b}$	$U_{B,c,f}$	$U_{B,c}$	$D_{B,c,b}$	$D_{B,c,f}$	$D_{B,c}$
1	0.35	1	0	0.5	0	0	0
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	0	0	0	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	1	0	0.5	0	0	0
7	1.88	0	0	0	1	0	0.5
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	1	0	0.5
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream correlation (five measurements)						Downstream correlation (five measurements)					$D_{c,tot}$
		1	2	3	4	5	$U_{c,tot}$	1	2	3	4	5	
1	0.35	38905	38496	38935	38496	38081	192913	36626	36167	36231	36352	35828	181204
2	0.47	23856	23507	23668	23595	23417	118043	25044	24396	24996	24970	24598	124004
3	0.62	14818	14707	14945	15014	14779	74263	15220	14901	15290	15359	15122	75892
4	0.84	15450	15295	15207	15493	15158	76603	15550	15241	15326	15354	15437	76908
5	1.14	4941	4998	5316	5374	5302	25931	4957	5094	5102	5144	5267	25564
6	1.44	4448	4608	4702	4887	4878	23523	4232	4193	4412	4372	4565	21774
7	1.88	5650	5821	5861	6127	6196	29655	5695	5768	6058	6212	6183	29916
8	2.57	3675	3724	3794	3887	4029	19109	3772	3888	4055	4154	4100	19969
9	3.46	2554	2589	2524	2662	2725	13054	2555	2689	2797	2804	2858	13703
10	4.69	1190	1263	1327	1304	1292	6376	1333	1455	1365	1502	1369	7024
11	6.20	305	331	344	299	331	1610	347	366	335	357	331	1736
12	8.37	232	258	231	276	265	1262	283	275	248	270	259	1335

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Correlation ratios (five measurements)						R_{avg}	Pass/Fail	Uncertainty limits		
		R_1	R_2	R_3	R_4	R_5	δ_c			e_c	Pass/Fail	
1	0.35	0.941	0.940	0.931	0.944	0.941	0.939	Pass	0.0052	0.0065	Pass	
2	0.47	1.050	1.038	1.056	1.058	1.050	1.050	Pass	0.0080	0.0099	Pass	
3	0.62	1.027	1.013	1.023	1.023	1.023	1.022	Pass	0.0052	0.0064	Pass	
4	0.84	1.006	0.996	1.008	0.991	1.018	1.004	Pass	0.0106	0.0132	Pass	
5	1.14	1.003	1.019	0.960	0.957	0.993	0.987	Pass	0.0273	0.0338	Pass	
6	1.44	0.951	0.910	0.938	0.895	0.936	0.926	Pass	0.0231	0.0287	Pass	
7	1.88	1.008	0.991	1.034	1.014	0.998	1.009	Pass	0.0164	0.0204	Pass	
8	2.57	1.026	1.044	1.069	1.069	1.018	1.045	Pass	0.0236	0.0293	Pass	
9	3.46	1.000	1.039	1.108	1.053	1.049	1.050	Pass	0.0387	0.0480	Pass	
10	4.69	1.120	1.152	1.029	1.152	1.060	1.102	Pass	0.0559	0.0694	Pass	
11	6.20	1.138	1.106	0.974	1.194	1.000	1.082	Pass	0.0930	0.1155	Pass	
12	8.37	1.220	1.066	1.074	0.978	0.977	1.063	Pass	0.0990	0.1229	Pass	

Symbols and units

- \bar{d}_i Geometric mean diameter of a size range i, µm
- $U_{B,c,b}$ Upstream beginning background count for correlation
- $U_{B,c,f}$ Upstream final background count
- $U_{B,c}$ Upstream background count average for correlation
- $D_{B,c,b}$ Downstream beginning background count for correlation
- $D_{B,c,f}$ Downstream final background count
- $D_{B,c}$ Downstream background count average for correlation
- $U_{c,tot}$ Total upstream particle counts
- $D_{c,tot}$ Total of the downstream particle counts
- R_{avg} Average correlation ratio
- δ_c Standard deviation of the correlation values
- e_c Uncertainty at 95 % confidence interval for correlation values



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Conditioned efficiency data
EN ISO 16890-2:2016

Air filter: UAB FIBERTON 592x592x48
Test no.: 224772
Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)
Air flow rate: 0.944 m³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,e,b}$	$U_{B,e,f}$	$U_{B,e}$	$D_{B,e,b}$	$D_{B,e,f}$	$D_{B,e}$
1	0.35	0	0	0	1	1	1
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	0	0	0	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	0	1	0.5	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream efficiency (five measurements)						Downstream efficiency (five measurements)					
		1	2	3	4	5	$U_{e,tot}$	1	2	3	4	5	$D_{e,tot}$
1	0.35	38433	38812	38700	38803	38566	193314	33665	34243	34205	34513	34096	170722
2	0.47	23262	23597	23657	23627	23598	117741	22248	22571	22242	22562	22488	112111
3	0.62	14805	14747	14771	15124	14581	74028	12878	12901	12857	12923	12862	64421
4	0.84	15286	15461	15080	15353	15290	76470	11451	11539	11720	11757	11789	58256
5	1.14	4766	4910	4768	4923	5085	24452	2509	2727	2612	2599	2671	13118
6	1.44	4384	4539	4442	4591	4627	22583	1789	1979	1951	1876	1915	9510
7	1.88	5648	5753	5760	5792	5762	28715	2284	2211	2227	2195	2236	11153
8	2.57	3552	3726	3762	3753	3688	18481	1161	1156	1192	1166	1200	5875
9	3.46	2543	2711	2623	2714	2581	13172	573	626	565	595	631	2990
10	4.69	1219	1269	1302	1268	1227	6285	248	255	231	236	241	1211
11	6.20	334	348	334	332	364	1712	55	55	60	53	55	278
12	8.37	307	312	325	288	276	1508	59	54	42	41	35	231

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Observed penetration (five measurements)							δ_o
		P_{o1}	P_{o2}	P_{o3}	P_{o4}	P_{o5}	P_o		
1	0.35	0.876	0.882	0.884	0.889	0.884	0.883	0.005	
2	0.47	0.956	0.957	0.940	0.955	0.953	0.952	0.007	
3	0.62	0.870	0.875	0.870	0.854	0.882	0.870	0.010	
4	0.84	0.749	0.746	0.777	0.766	0.771	0.762	0.014	
5	1.14	0.526	0.555	0.548	0.528	0.525	0.537	0.014	
6	1.44	0.408	0.436	0.439	0.409	0.414	0.421	0.015	
7	1.88	0.404	0.384	0.387	0.379	0.388	0.388	0.010	
8	2.57	0.327	0.310	0.317	0.311	0.325	0.318	0.008	
9	3.46	0.225	0.231	0.215	0.219	0.244	0.227	0.011	
10	4.69	0.203	0.201	0.177	0.186	0.196	0.193	0.011	
11	6.20	0.165	0.158	0.180	0.160	0.151	0.163	0.011	
12	8.37	0.192	0.173	0.129	0.142	0.127	0.153	0.029	

OPC Bin, i	\bar{d}_i µm	Penetration data reduction			Uncertainty limits			Efficiency %
		P	δ	e	Static	Dynamic	Pass/Fail	
1	0.35	0.940	0.007	0.009	0.05	0.066	Pass	6.0
2	0.47	0.906	0.009	0.012	0.05	0.063	Pass	9.4
3	0.62	0.852	0.011	0.013	0.05	0.060	Pass	14.8
4	0.84	0.759	0.016	0.020	0.05	0.053	Pass	24.1
5	1.14	0.544	0.021	0.026	0.05	0.038	Pass	45.6
6	1.44	0.455	0.020	0.025	0.05	0.032	Pass	54.5
7	1.88	0.385	0.011	0.014	0.05	0.027	Pass	61.5
8	2.57	0.304	0.010	0.013	0.05	0.021	Pass	69.6
9	3.46	0.216	0.013	0.017	0.05	0.032	Pass	78.4
10	4.69	0.175	0.013	0.016	0.05	0.026	Pass	82.5
11	6.20	0.150	0.016	0.020	0.05	0.030	Pass	85.0
12	8.37	0.144	0.030	0.037	0.05	0.029	Pass	85.6

Symbols and units



- \bar{d}_i Geometric mean diameter of a size range i, µm
- $U_{B,e,b}$ Upstream beginning background count for penetration
- $U_{B,e,f}$ Upstream final background count
- $U_{B,e}$ Upstream background count average for penetration
- $D_{B,e,b}$ Downstream beginning background count for penetration
- $D_{B,e,f}$ Downstream final background count
- $D_{B,e}$ Downstream background count average for penetration
- $U_{e,tot}$ Total upstream particle counts
- $D_{e,tot}$ Total downstream particle counts
- P_o Observed penetration, -
- P Penetration, -
- δ_o Standard deviation of the observed penetration
- δ Standard deviation of the penetration
- e Uncertainty at 95 % confidence interval for penetration values



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Normalized downstream particle size distribution and measured efficiencies
EN ISO 16890-1,2,4:2016

Air filter: UAB FIBERTON 592x592x48
 Test no.: 224772
 Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)
 Air flow rate: 0.944 m³/s



Particle size			Urban size distribution					Rural size distribution			Fractional efficiency		
Δd_i µm	\bar{d}_i µm	$\Delta \ln d_i$ µm	$q_{3u}(\bar{d}_i)$	$E_i^* q_{3u}(\bar{d}_i)$ $\Delta \ln d_i$	$E_{D,i}^* q_{3u}(\bar{d}_i)$ $\Delta \ln d_i$	$E_{A,i}^* q_{3u}(\bar{d}_i)$ $\Delta \ln d_i$	$q_{3r}(\bar{d}_i)$	$q_{3r}(\bar{d}_i)^*$ $\Delta \ln d_i$	$E_{A,i}^* q_{3r}(\bar{d}_i)$ $\Delta \ln d_i$	Initial, E_i %	Conditioned $E_{D,i}$ %	Average $E_{A,i}$ %	
0.30 - 0.41	0.35	0.31237	0.22568	0.070498	0.010169	0.004218	0.007193	0.093806	0.029303	0.002990	14	6	10
0.41 - 0.55	0.47	0.29376	0.19732	0.057965	0.011115	0.005423	0.008269	0.083478	0.024522	0.003498	19	9	14
0.55 - 0.70	0.62	0.24116	0.15837	0.038193	0.010043	0.005665	0.007854	0.074324	0.017924	0.003686	26	15	21
0.70 - 1.00	0.84	0.35667	0.11522	0.041097	0.014105	0.009912	0.012008	0.070137	0.025016	0.007310	34	24	29
1.00 - 1.30	1.14	0.26236	0.08503	0.022309	0.013108	0.010176	0.011642	0.076281	0.020013	0.010444	59	46	52
1.30 - 1.60	1.44	0.20764	0.07618	0.015817	0.010337	0.008624	0.009480	0.088326	0.018340	0.010992	65	55	60
1.60 - 2.20	1.88	0.31845	0.08022	0.025546	0.018127	0.015709	0.016918	0.108042	0.034406	0.022786	71	61	66
2.20 - 3.00	2.57	0.31015	0.09984	0.030966	0.024236	0.021543	0.022890	0.137262	0.042573	0.031470	78	70	74
3.00 - 4.00	3.46	0.28768	0.12688	0.036500	0.031069	0.028605	0.029837	0.167084	0.048067	0.039293	85	78	82
4.00 - 5.50	4.69	0.31845	0.15556	0.049537	0.042952	0.040871	0.041911	0.195424	0.062233	0.052653	87	83	85
5.50 - 7.00	6.20	0.24116	0.17757	0.042823	0.036359	0.036388	0.036373	0.216707	0.052261	0.044391	85	85	85
7.00 - 10.00	8.37	0.35667	0.19157	0.068329	0.059904	0.058511	0.059208	0.231428	0.082545	0.071526	88	86	87

Symbols and units

- Δd_i Particle size range, µm
- \bar{d}_i Geometric mean diameter of a size range i , µm
- $\Delta \ln d_i$ Logarithmic width of particle diameter size range i
- $q_{3u}(\bar{d}_i)$ Discrete urban particle volume distribution, dimensionless
- $q_{3r}(\bar{d}_i)$ Discrete rural particle volume distribution, dimensionless
- E_i Initial fractional efficiency of particle size range i of the untreated and unloaded filter element, %
- $E_{D,i}$ Fractional efficiency of particle size range i of the filter element after an artificial conditioning step, %
- $E_{A,i}$ Average fractional efficiency of particle size range i , %
- $ePM_{x,ini}$ Initial particulate matter efficiency value of the clean filter, %
- $ePM_{x,min}$ Minimum particulate matter efficiency value of the conditioned filter, %
- ePM_x Particulate matter efficiency, %

Particulate matter efficiencies		
$ePM_{1,ini}$	$ePM_{1,min}$	ePM_1
22 %	12 %	17 %
$ePM_{2.5,ini}$	$ePM_{2.5,min}$	$ePM_{2.5}$
37 %	27 %	32 %
$ePM_{10,ini}$	$ePM_{10,min}$	ePM_{10}
69 %	63 %	66 %
ISO ePM_{10} 65 %		



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

**The interpretation of test reports
ISO 16890-1:2016**

This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary (for further details of procedures, the full ISO 16890 document series shall be consulted).

Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency ("mechanical efficiency") as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when, at the same time, there is no compensating increase of the mechanical efficiency.

These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible "real-life" behaviour.

Instrument	Instruments used in the test			
	Type code	Serial number	Calibration date	Used
Micromanometer	Furness C012	209103	15.7.2022	X
	Furness C012	1211165	15.7.2022	X
	Micatrone MF-PD	32760-068	15.7.2022	X
Barometer	Vaisala PTB330	F4340001	18.7.2022	X
Hygrometer	Vaisala HMT333	D3940024	8.12.2022	X
Temperature meter	Agilent 34970A	MY44034623	3.10.2022	X
Balance	Precisa XB10200D-IP65	5300037	11.1.2022	X
	DFWATEX2GD-1	93411584	11.1.2022	X
Particle counter	TSI 3330	3330152501	11.1.2022	X
	TSI 3330	3330160801	12.1.2022	X
DEHS aerosol generator	ISO 16890-2:2016	-	-	X
KCl aerosol generator	TSI 8108	8108153201	-	X
Dust feeder	TOPAS SAG 440	440 13 03 406	3.10.2022	X
Orifice plate	Ø 216 mm / (610 x 610) mm	-	7.12.2020	X
	Ø 272 mm / (610 x 610) mm	-	7.12.2020	-
	Ø 90 mm / (610 x 610) mm	-	7.12.2020	-